AXAL® PRO SALT TABLETS



Pure dried vacuum salt

ΕN

Quality	completely soluble special salt
~	completely columns openial call

Chemical Analysis	w	typical	min.	max.	Method
 Sodium chloride 	[%]	99.93	99.9		EN 973
Calcium (Ca) + Magnesium (Mg) [%]	0.004		0.01	ISO 2482
 Sulphate (SO₄) 	[%]	0.04		0.1	ISO 2480
 H₂O-insoluble 	[%]	0.005		0.01	ISO 2479
Moisture	[%]	0.02		0.1	ISO 2483
Lead (Pb)	[mg/kg]	0.5		1	EN 973
Antimony (Sb)	[mg/kg]	0.1		2.6	EN 973
Selenium (Se)	[mg/kg]	0.1		2.6	EN 973
Iron (Fe)	[mg/kg]	1		2	EuSalt AS 015
Manganese (Mn)	[mg/kg]	0.1		1	EuSalt AS 015
Arsenic (As)	[mg/kg]	0.1		0.3	EN 973
Cadmium (Cd)	[mg/kg]	0.1		0.5	EN 973
Chromium (Cr)	[mg/kg]	0.1		0.75	EN 973
Mercury (Hg)	[mg/kg]	0.02		0.05	EN 973
Copper (Cu)	[mg/kg]	0.1		2	EuSalt AS 015
Nickel (Ni)	[mg/kg]	0.1		0.75	EN 973
Granulometry according to EN 1235	w	typical		max.	
Fine fraction <5.0 mm	[%]	2		4	

Dimensions

The data given above are based on our continuous quality monitoring system. They do not exempt the user from his obligation to make an incoming inspection of the delivered product. The data are for information purposes and do not constitute any guarantee. It is the responsibility of the user to determine the product's suitability for his intended use.



AXAL® PRO SALT TABLETS



Pure dried vacuum salt

Height 16.00 mm
 Diameter 25.00 mm
 Weight 15.00 g

Field of application

 AXAL® PRO tablets are specially produced to obtain a very pure brine for regeneration of ion exchange resins in water softeners.

Note

ΕN

Typical values on basis of regular analysis.

Note

- This product is in compliance with EN 973(A): regenerating salt for ion exchangers.
- EN 973: Chemicals used for treatment of water intended for human consumption -Sodium chloride for regeneration of ion exchangers.

Note

 The tablets are produced from refined food grade salt which complies with the purity criterion of the Codex Alimentarius.

Note

Strictly follow instructions of the manufacturer.

Application

For industrial uses.

The data given above are based on our continuous quality monitoring system. They do not exempt the user from his obligation to make an incoming inspection of the delivered product. The data are for information purposes and do not constitute any guarantee. It is the responsibility of the user to determine the product's suitability for his intended use.

